

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

School: P.S. 43 - BRONX, 165 BROWN PLACE, BRONX, NY, 10454

InspectionId	Inspection Type	Time In	Last Edited
1560024	ELECTRICAL	2010-10-21 08:46AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Fire Alarm System Years: Under Construction Systems: Public Address System Years: Under Construction Systems: Local Sound System in Auditorium, Cafeteria, Gymnasium, Multipurpose Rooms Years: Under Construction Systems: Emergency/Exit Light Panel, Partial Service Switch Years: 2003 Systems: Emergency Light   Battery Packs Years: 2001-2002 Systems: Service Switch Years: 2003 Systems: LAN   I / Local Distribution Frames Years: 2008 Systems: LAN   Main Distribution Frame / Partial Years: 2000 and 2008 Systems: Exit Light   Battery Packs Years: 2001-2002 Systems: Telephone Systems Years: 2001-2002 Systems: Lighting - Security Lights Years: 2000-2001 Systems: Panel Board   Molded Case Circuit Breaker Type Years: 1990 and 1998 - Estimated Systems: Intrusion Alarm Years: 2006
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	Ground Floor
<b>HOUSE LIGHTING</b>	
Instance on Ground Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency Quantity	59
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Ground Floor	Under construction
<b>PROJECTION SYSTEM</b>	
Instance on Ground Floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Ground Floor	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Ground floor
<b>LIGHTING</b>	
Instance on Ground floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	61
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Ground floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Ground floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Ground floor	Under construction
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
LIGHTING	Inspected

NYC Department of Education  
Building Condition Assessment Survey 2010-2011

*Electrical Inspection*

**X043**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,144
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	29
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 412
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 412	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 412	Inspected
<b>Pendant Mounted</b>	
Instance on Room 412	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 412	Does not exist
<b>Surface Mounted</b>	
Instance on Room 412	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 412	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 412	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 412	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHTING</b>	
<b>BATTERY PACK</b>	
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOFF PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	FARADAY
EquipmentId	FIRE ALARM
Capacity/Size	5 circuits
Installation Year	1950
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	97,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>STROBE</b>	Does not exist
<b>SUB-PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm Control Board
Capacity/Size	2 circuits
Installation Year	1950
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TAMPER FLOW SWITCH/CHAIN</b>	Does not exist
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	Ground Floor
<b>LIGHTING</b>	
Instance on Ground Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 406
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 406	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 406	Inspected
<b>Pendant Mounted</b>	
Instance on Room 406	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	29
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 406	Does not exist
<b>Surface Mounted</b>	
Instance on Room 406	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 406	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 406	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 406	Does not exist
<b>SMART BOARD</b>	
Instance on Room 406	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	4- Between Fair and Poor

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>LIGHTING - SECURITY LIGHTS</b>	
Replacement Quantity	10
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Around Perimeter of Building
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	
	Does not exist
<b>LOCKER ROOM</b>	
	Does not exist
<b>MOTOR CONTROL CENTER</b>	
	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	
	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	
	Inspected
Instance	Ground Floor - North
Instance	Ground Floor - South
Instance	Room 401
Instance	Room 405
<b>LIGHTING</b>	
Instance on Ground Floor - North	Inspected
Instance on Ground Floor - South	Inspected
Instance on Room 401	Inspected
Instance on Room 405	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Does not exist
Instance on Room 405	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Does not exist
Instance on Room 405	Inspected
<b>Pendant Mounted</b>	
Instance on Room 405	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 405	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

Question	Response
<b>MULTIPURPOSE ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
<b>Recessed Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 405	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor - North	Inspected
Instance on Ground Floor - South	Inspected
Instance on Room 401	Inspected
Instance on Room 405	Does not exist
<b>Pendant Mounted</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Does not exist
<b>Recessed Mounted</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Ground Floor - North	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Ground Floor - South	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>MULTIPURPOSE ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 401	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Ground Floor - North	Under construction
Instance on Ground Floor - South	Under construction
Instance on Room 401	Does not exist
Instance on Room 405	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Does not exist
Instance on Room 405	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Ground Floor - North	Does not exist
Instance on Ground Floor - South	Does not exist
Instance on Room 401	Does not exist
Instance on Room 405	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room, Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Near Auditorium Stage
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Under construction
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

Question	Response
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista 128B
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	
	Does not exist
<b>SERVICE SWITCH</b>	
	Inspected
Instance	Electrical Room in vicinity of Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard / Siemens
EquipmentId	N/A
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	2003
Source of Installation Year	Documented
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
<b>AIR CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	
	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	
	Inspected
Instance	Electrical Room in vicinity of Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	1000 Amps total, 3 sections
Source of Capacity/Size	Switchboard Mains Size

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED KNIFE SWITCH TYPE</b>	
Installation Year	1922
Source of Installation Year	Estimated
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X043**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	No
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist