

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

School: **I.S. 125 - BRONX, 1111 PUGSLEY AVENUE, BRONX, NY, 10472**

InspectionId	Inspection Type	Time In	Last Edited
1570053	ELECTRICAL	2010-11-23 08:25AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: 24 Hour Panel Board Years: 2009 Systems: Intrusion Alarm System Years: 1996 Systems: Partial Panel Boards (Molded Case) Years: 1978, 1998 Systems: Switchboard and Service Switch Years: 1978 Systems: Lighting In The Library Years: 1995 Systems: Smart Boards Years: 2009, 2010 Systems: Emergency Lights and Exit Lights Fixtures (Battery Packs) Years: 2003, 2009 Systems: Emergency light /Exit Light Panel Years: 1992 Systems: Security CCTV System Years: 2010 Systems: Public Address System and Local Sound Systems Years: 2009 Systems: Exterior Lighting (New Ballasts and New Bulbs) Years: 2009 Systems: Telephone System and LAN system Years: 2007 Systems: Score Board In The Gymnasium Years: 2007 Systems: Sprinkler Flow /Air Pressure Switch Years: 2008 Type of Service Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st floor
<b>HOUSE LIGHTING</b>	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Does not exist
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Inspected
<b>Dimming System</b>	
Instance on 1st floor	Does not exist
<b>Theater Lighting</b>	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	62
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	26

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Theater Lighting</b>	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Basement-Staff
Instance	Basement-Students
<b>LIGHTING</b>	
Instance on Basement-Staff	Inspected
Instance on Basement-Students	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement-Staff	Inspected
Instance on Basement-Students	Inspected
<b>Pendant Mounted</b>	
Instance on Basement-Staff	Does not exist
Instance on Basement-Students	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement-Staff	Does not exist
Instance on Basement-Students	Does not exist
<b>Surface Mounted</b>	
Instance on Basement-Staff	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement-Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	108
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement-Staff	Does not exist
Instance on Basement-Students	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement-Staff	Does not exist
Instance on Basement-Students	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement-Staff	Does not exist
Instance on Basement-Students	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LOCAL SOUND SYSTEM</b>	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,430
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Does not exist	
<b>Surface Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	190
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Does not exist	
<b>Lighting Fixture - Incandescent</b>	
Inspected	
<b>Pendant Mounted</b>	
Inspected	
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	
Instance	Room 219
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 261
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 370
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 219	Inspected
Instance on Room 261	Inspected
Instance on Room 370	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 219	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 261	Inspected
Instance on Room 370	Inspected
<b>Pendant Mounted</b>	
Instance on Room 219	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 261	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 370	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 219	Does not exist
Instance on Room 261	Does not exist
Instance on Room 370	Does not exist
<b>Surface Mounted</b>	
Instance on Room 219	Does not exist
Instance on Room 261	Does not exist
Instance on Room 370	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 219	Does not exist
Instance on Room 261	Does not exist
Instance on Room 370	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 219	Does not exist
Instance on Room 261	Does not exist
Instance on Room 370	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 219	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 261	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 370	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE POORLY MOUNTED
Deficiency Location/Instance	2nd floor Corridor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	2nd floor Corridor Stair B, Boys Lockers, Exit 5 in the Gymnasium And Girls Locker
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>FUSED CUTOFF PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Fire Alarm
Capacity/Size	8 Circuits
Installation Year	1952
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	147,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Does not exist
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STROBE</b>	Does not exist
<b>SUB-PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Fire Alarm Control Panel
Capacity/Size	2 Circuits

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>SUB-PANEL</b>	
<b>Fire Alarm Control Panel (Standard)</b>	
Installation Year	1952
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	N/A
Capacity/Size	2 Circuits
Installation Year	1952
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Instance	Inspected
Instance	Basement
<b>LIGHTING</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCOREBOARD</b>	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Basement	Does not exist
<b>INTERCOM SYSTEM</b>	
Instance on Basement	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
Instance	Basement
<b>LIGHTING</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	64
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 211
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 211	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 211	Inspected
<b>Pendant Mounted</b>	
Instance on Room 211	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 211	Does not exist
<b>Surface Mounted</b>	
Instance on Room 211	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 211	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 211	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 211	Does not exist
<b>SMART BOARD</b>	
Instance on Room 211	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	3- Fair
Replacement Quantity	15
Replacement Uom	EACH
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	
Instance on Basement-B31 Girls	Inspected
Alternative Use	No
Instance on Basement-Boys	Inspected
Alternative Use	Yes
<b>LIGHTING</b>	
Instance on Basement-B31 Girls	Inspected
Instance on Basement-Boys	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement-B31 Girls	Inspected
Instance on Basement-Boys	Does not exist
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on Basement-B31 Girls	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement-B31 Girls	Does not exist
<b>Surface Mounted</b>	
Instance on Basement-B31 Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement-B31 Girls	Does not exist
Instance on Basement-Boys	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement-B31 Girls	Inspected
Instance on Basement-Boys	Inspected
<b>Pendant Mounted</b>	
Instance on Basement-B31 Girls	Does not exist
Instance on Basement-Boys	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement-B31 Girls	Does not exist
Instance on Basement-Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement-B31 Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement-Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Rooms and Basement
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Room and Basement
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>FUSED KNIFE SWITCH TYPE</b>	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED TOGGLE SWITCH TYPE</b>	
	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors and Basement
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	General Office
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 249	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 347	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 349	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 351	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>LIGHTING</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
Instance on Room 249	Inspected
Instance on Room 347	Inspected
Instance on Room 349	Inspected
Instance on Room 351	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 249	Inspected
Instance on Room 347	Inspected
Instance on Room 349	Inspected
Instance on Room 351	Inspected
<b>Pendant Mounted</b>	
Instance on Room 249	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 347	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 349	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 351	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>SMART BOARD</b>	
Instance on Room 249	Does not exist
Instance on Room 347	Does not exist
Instance on Room 349	Does not exist
Instance on Room 351	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 243	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 343	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 247	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 326	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 243	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 343	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 247	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 326	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Does not exist
<b>LIGHTING</b>	
Instance on Room 243	Inspected
Instance on Room 343	Inspected
Instance on Room 247	Inspected
Instance on Room 326	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 243	Inspected
Instance on Room 343	Inspected
Instance on Room 247	Inspected
Instance on Room 326	Inspected
<b>Pendant Mounted</b>	
Instance on Room 243	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 343	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 247	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 326	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Does not exist
<b>Surface Mounted</b>	
Instance on Room 243	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 343	Does not exist
Instance on Room 247	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 326	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 243	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

Question	Response
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Inspected
<b>Instructor Unit</b>	
Instance on Room 326	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 326	Does not exist
<b>Student Unit</b>	
Instance on Room 326	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 247	Does not exist
Instance on Room 326	Does not exist
<b>SMART BOARD</b>	
Instance on Room 243	Does not exist
Instance on Room 343	Does not exist
Instance on Room 247	Does not exist
Instance on Room 326	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance on Room 245	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance on Room 345	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>LIGHTING</b>	
Instance on Room 245	Inspected
Instance on Room 345	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 245	Inspected
Instance on Room 345	Inspected
<b>Pendant Mounted</b>	
Instance on Room 245	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 345	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>Surface Mounted</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 245	Does not exist
Instance on Room 345	Does not exist
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	
Instance	Custodian's Office
Instance Condition	3- Fair
Instance Quantity	1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	
Instance Quantity Uom	EACH
Model	Vista 50P
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
Condition	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Condition	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Service SW. Distr. SWBD
Capacity/Size	3000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1978
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	
Condition	Does not exist
<b>SWITCHBOARD</b>	
Condition	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	2
<b>AIR CIRCUIT BREAKER TYPE</b>	
Condition	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Condition	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size	3000 Amps total, 5 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	1978
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	
	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>TELEPHONE</b>	
	Inspected
<b>PBX/INTERCOM</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STANDARD</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	
	Inspected
<b>LIGHTING</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X125**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist