

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

School: **I.S. 184 - BRONX, 778 FOREST AVENUE, BRONX, NY, 10456**

InspectionId	Inspection Type	Time In	Last Edited
1570101	ELECTRICAL	2011-02-04 08:37AM	2011-05-04 10:35AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Fire Alarm System Years: 2010 Systems: Public Address System and Local Sound Systems Years: 2010 Systems: Security Lights and CCTV Years: 2010 Systems: Projector In Auditorium Years: 2006 Systems: LAN Years: 2006 Systems: Emergency Light/Exit Light Panel Years: 2004 Systems: Partial Emergency Lights With Battery Packs Years: 2006 Systems: Intrusion Alarm System Years: Approximately 1990 Systems: Partial Battery Packs For Emergency Lights Years: 2010 Systems: Intrusion Alarm Panic Switch Years: Under Construction Systems: Smart Boards Years: 2008 Systems: Partial Exit Lights with Battery Packs Years: 2010 Systems: Partial Intrusion Sensors Years: 2010
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Elevator Intercom Not Operational	Elevator	Elevator	Fireman: Gilbert Vasquez

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	137
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	5- Poor
Deficiency	LIGHT CONSOLE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	84
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	67
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	1st floor Students
Instance	Room 152- Students
LIGHTING	
Instance on 1st floor Students	Inspected
Instance on Room 152- Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on 1st floor Students	Inspected
Instance on Room 152- Students	Inspected
Pendant Mounted	
Instance on 1st floor Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	52
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 152- Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	100
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 152- Students	Does not exist
Surface Mounted	
Instance on 1st floor Students	Does not exist
Instance on Room 152- Students	Does not exist
Lighting Fixture - HID	
Instance on 1st floor Students	Does not exist
Instance on Room 152- Students	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor Students	Does not exist
Instance on Room 152- Students	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
CAFETERIA	
LOCAL SOUND SYSTEM	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 152- Students	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,420
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency Quantity	580
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	90
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	
Instance	Inspected
Has LAN/Modem access	Roams 307 and 321
Power Panel?	Yes
Instance	Yes
Has LAN/Modem access	Room 214
Power Panel?	Yes
Instance	No
Has LAN/Modem access	
Power Panel?	
LIGHTING	
Instance on Roams 307 and 321	Inspected
Instance on Room 214	Inspected
Lighting Fixture - Fluorescent	
Instance on Roams 307 and 321	Inspected
Instance on Room 214	Inspected
Pendant Mounted	
Instance on Roams 307 and 321	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	45
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 214	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Rooms 307 and 321	Does not exist
Instance on Room 214	Does not exist
Surface Mounted	
Instance on Rooms 307 and 321	Does not exist
Instance on Room 214	Does not exist
Lighting Fixture - HID	
Instance on Rooms 307 and 321	Does not exist
Instance on Room 214	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 307 and 321	Does not exist
Instance on Room 214	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Rooms 307 and 321	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 214	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Inspected
Condition	3- Fair
Deficiency	BATTERY BANK NOT IN USE
Deficiency Location/Instance	Electrical Room - Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
EXIT LIGHT	
Non Battery Pack	
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Locker Rooms 131 and 141 and Corridor by Room 238
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Inspected
Instance	Main Entrance Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Notifier
EquipmentId	Central Office Transmitter
Capacity/Size	2 Zones
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED CUTOFF PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	1- Good
Instance Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
FIRE ALARM SYSTEM	
MAIN PANEL	
Fire Alarm Control Panel (Electronic)	
Instance Quantity Uom	EACH
Manufacturer	Notifier
Model	Notifier
EquipmentId	Temporal 3 Fire Alarm System
Capacity/Size	24 Zones
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Pendant Mounted	
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 1st floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	5- Poor
Deficiency	INTERCOM CABINET NOT OPERATIONAL
Deficiency Location/Instance	Elevator
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 236
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 236	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 236	Inspected
Pendant Mounted	
Instance on Room 236	Does not exist
Recessed Mounted	
Instance on Room 236	Does not exist
Surface Mounted	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 236	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 236	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
LIBRARY	
SMART BOARD	
Instance on Room 236	Does not exist
LIGHTING - SECURITY LIGHTS	
	Inaccessible
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM	
Instance on Room 114-Boys And Room 131-Girls	Inspected
Alternative Use	Yes
LIGHTING	
Instance on Room 114-Boys And Room 131-Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 114-Boys And Room 131-Girls	Does not exist
Lighting Fixture - HID	
Instance on Room 114-Boys And Room 131-Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 114-Boys And Room 131-Girls	Inspected
Pendant Mounted	
Instance on Room 114-Boys And Room 131-Girls	Does not exist
Recessed Mounted	
Instance on Room 114-Boys And Room 131-Girls	Does not exist
Surface Mounted	
Instance on Room 114-Boys And Room 131-Girls	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	41
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	
Instance	Inspected
Instance	Room 329
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric
EquipmentId	N/A
Capacity/Size	380 Amps, 2 Sections
Installation Year	1975
Source of Installation Year	Documented
Deficiency	MCC INDICATOR LIGHT NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC ID IS MISSING

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
MOTOR CONTROL CENTER	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 201
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Telecor II
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	
Instance on Rooms 216, 218 and 320	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 318	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 216, 218 and 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 318	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 216, 218 and 320	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance on Room 318	Does not exist
LIGHTING	
Instance on Rooms 216, 218 and 320	Inspected
Instance on Room 318	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 216, 218 and 320	Inspected
Instance on Room 318	Inspected
Pendant Mounted	
Instance on Rooms 216, 218 and 320	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	64
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 318	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
Surface Mounted	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
Lighting Fixture - HID	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
POWER SUPPLY	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
PROJECTION SYSTEM	
Instance on Rooms 216, 218 and 320	Does not exist
Instance on Room 318	Does not exist
SMART BOARD	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
SCIENCE LAB	
SMART BOARD	
Instance on Rooms 216, 218 and 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 318	Does not exist
SCIENCE PREP ROOM	
Instance on Room 227	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 227	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 227	Does not exist
LIGHTING	
Instance on Room 227	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 227	Inspected
Pendant Mounted	
Instance on Room 227	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 227	Does not exist
Surface Mounted	
Instance on Room 227	Does not exist
Lighting Fixture - HID	
Instance on Room 227	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 227	Inspected
Pendant Mounted	
Instance on Room 227	Does not exist
Recessed Mounted	
Instance on Room 227	Does not exist
Surface Mounted	
Instance on Room 227	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
POWER SUPPLY	
Instance on Room 227	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office-Room 101
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Under construction
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV SYSTEM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room (B17)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Co.
EquipmentId	Main Service Sw.
Capacity/Size	N/A
Source of Capacity/Size	None
Installation Year	1975
Source of Installation Year	Documented
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	1
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room (B17)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Co.
EquipmentId	N/A
Capacity/Size	N/A Amps total, 5 Sections
Source of Capacity/Size	None.

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Installation Year	1975
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room (B17)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Co.
EquipmentId	N/A
Capacity/Size	N/A Amps total, 1 Section
Source of Capacity/Size	None.
Installation Year	1975
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X184

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	72
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist