

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

School: BRONX REGIONAL HS (OLD 133) - X, 1010 REV. J.A. POLITE AVENUE, BRONX, NY, 10459

InspectionId	Inspection Type	Time In	Last Edited
1570064	ELECTRICAL	2010-12-09 08:28AM	2011-04-21 01:23PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Panel Boards Years: 2004 Systems: Dimming System, Stage Lighting in the Auditorium and Projection System. Years: 2007 Systems: Partial Exterior Lights (Near the Gymnasium) Years: 2006 Systems: Public Address System and Local Sound Systems Years: 2008 Systems: Fire Alarm System Years: 2007 Systems: General Lighting Throughout The Building Years: 1999 Systems: LAN and Telephone System Years: 2004 Systems: Science Labs 402 and 507 Years: 2004 Systems: Intrusion Alarm System Years: 2000 Systems: Lighting in The Gymnasium Years: 2005 Systems: Scoreboard In The Gymnasium Years: 2001 Systems: Exit and Emergency Lights Years: 1999 Systems: Computer Lab 201 (No Upgrade to the Room Except the Panel in 2004) Years: 2009. Systems: Smart Boards Years: 2007 Systems: CCTV Years: 2002
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Emergency Power Shut off Valve Not Operational	Emergency Power Shut Off Valve	Science Lab Room 507	Fireman : RICK SILAGYI
Emergency Gas Shut Off Valve not Operational	Emergency Gas Shut Off Valve	Science Lab Room 507	Fireman : RICK SILAGYI

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	4th floor
HOUSE LIGHTING	
Instance on 4th floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 4th floor	Inspected
Pendant Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 4th floor	Does not exist
Recessed Mounted	
Instance on 4th floor	Does not exist
Surface Mounted	
Instance on 4th floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 4th floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 4th floor	Inspected
Pendant Mounted	
Instance on 4th floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 4th floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Violations	No violations recorded
Surface Mounted	
Instance on 4th floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 4th floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 4th floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 4th floor	Inspected
Dimming System	
Instance on 4th floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 4th floor	Inspected
Instance Condition	1- Good
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	3rd floor
LIGHTING	
Instance on 3rd floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd floor	Inspected
Pendant Mounted	
Instance on 3rd floor	Does not exist
Recessed Mounted	
Instance on 3rd floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 3rd floor	Does not exist
Lighting Fixture - HID	
Instance on 3rd floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 3rd floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
CAFETERIA	
LOCAL SOUND SYSTEM	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	6
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Does not exist	
Lighting Fixture - Incandescent	
Inspected	
Pendant Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Rooms 201, 323, 431 and 527.
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Rooms 201, 323, 431 and 527.	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 201, 323, 431 and 527.	Inspected
Pendant Mounted	
Instance on Rooms 201, 323, 431 and 527.	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 201, 323, 431 and 527.	Does not exist
Surface Mounted	
Instance on Rooms 201, 323, 431 and 527.	Does not exist
Lighting Fixture - HID	
Instance on Rooms 201, 323, 431 and 527.	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 201, 323, 431 and 527.	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Rooms 201, 323, 431 and 527.	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Does not exist
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOOUT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
FIRE ALARM SYSTEM	
MAIN PANEL	
Fire Alarm Control Panel (Electronic)	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST-2
EquipmentId	Fire Command Station
Capacity/Size	15 zones
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
Does not exist	
MANUAL PULL STATION	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	
Inspected	
Display Monitor	
Does not exist	
Panel	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	
Inspected	
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	
Does not exist	
SPRINKLER FLOW/AIR PRESSURE SWITCH	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	
Does not exist	
TAMPER FLOW SWITCH/CHAIN	
Inspected	
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Inspected	
Instance	4th floor
LIGHTING	
Instance on 4th floor	
Inspected	
Lighting Fixture - Fluorescent	
Instance on 4th floor	
Does not exist	
Lighting Fixture - HID	
Instance on 4th floor	
Inspected	
Pendant Mounted	
Instance on 4th floor	
Inspected	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Pendant Mounted	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 4th floor	Does not exist
Surface Mounted	
Instance on 4th floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 4th floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 4th floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 4th floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 4th floor	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Instance	3rd floor
LIGHTING	
Instance on 3rd floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd floor	Inspected
Pendant Mounted	
Instance on 3rd floor	Does not exist
Recessed Mounted	
Instance on 3rd floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 3rd floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 3rd floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 435
Has LAN/Modem access	Yes
LIGHTING	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
LIBRARY	
LIGHTING	
Instance on Room 435	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 435	Inspected
Pendant Mounted	
Instance on Room 435	Does not exist
Recessed Mounted	
Instance on Room 435	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 435	Does not exist
Lighting Fixture - HID	
Instance on Room 435	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 435	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 435	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 435	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inspected
Condition	3- Fair
Replacement Quantity	22
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE PHOTOCCELL NOT OPERATIONAL
Deficiency Location/Instance	Rogers Place Side
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Rooms and Boiler Room
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
PANEL BOARD	
FUSED DISCONNECT SWITCH TYPE	
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Room and Basement
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors and Assembly Areas
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General office Room 449
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 407	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Rooms 303, 307 and 403	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
LIGHTING	
Instance on Room 407	Inspected
Instance on Rooms 303, 307 and 403	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 407	Inspected
Instance on Rooms 303, 307 and 403	Inspected
Pendant Mounted	
Instance on Room 407	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 303, 307 and 403	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
Surface Mounted	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
Lighting Fixture - HID	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
POWER SUPPLY	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
PROJECTION SYSTEM	
Instance on Room 407	Does not exist
Instance on Rooms 303, 307 and 403	Does not exist
SMART BOARD	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 303, 307 and 403	Does not exist
SCIENCE LAB	
Instance on Room 503	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 507	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Rooms 402	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 503	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	5- Poor

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SCIENCE LAB	
EMERGENCY GAS SHUT-OFF VALVE	
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Rooms 402	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 503	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Rooms 402	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 503	Inspected
Instance on Room 507	Inspected
Instance on Rooms 402	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 503	Inspected
Instance on Room 507	Inspected
Instance on Rooms 402	Inspected
Pendant Mounted	
Instance on Room 503	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 402	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
Instance on Rooms 402	Does not exist
Surface Mounted	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
Instance on Rooms 402	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - HID	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
Instance on Rooms 402	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 503	Inspected
Instance on Room 507	Inspected
Instance on Rooms 402	Does not exist
Pendant Mounted	
Instance on Room 503	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
Surface Mounted	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
POWER SUPPLY	
Instance on Room 503	Inspected
Instance on Room 507	Inspected
Instance on Rooms 402	Does not exist
Instructor Unit	
Instance on Room 503	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 503	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 503	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 503	Does not exist
Instance on Room 507	Does not exist
Instance on Rooms 402	Does not exist
SMART BOARD	
Instance on Room 503	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SCIENCE LAB	
SMART BOARD	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 402	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance on Doods 405 and 503 A	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Doods 405 and 503 A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Doods 405 and 503 A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Doods 405 and 503 A	Inspected
Lighting Fixture - Fluorescent	
Instance on Doods 405 and 503 A	Inspected
Pendant Mounted	
Instance on Doods 405 and 503 A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Doods 405 and 503 A	Does not exist
Surface Mounted	
Instance on Doods 405 and 503 A	Does not exist
Lighting Fixture - HID	
Instance on Doods 405 and 503 A	Does not exist
Lighting Fixture - Incandescent	
Instance on Doods 405 and 503 A	Does not exist
POWER SUPPLY	
Instance on Doods 405 and 503 A	Does not exist
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Custodian's Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SECURITY	
INTRUSION ALARM	
Panic Switch	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric
EquipmentId	Main
Capacity/Size	2500 Amps
Source of Capacity/Size	Nameplate
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
Water Penetration In Electrical Room?	No
Number of Spares	1
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric
EquipmentId	N/A
Capacity/Size	2500 Amps total, 3 Sections
Source of Capacity/Size	Service Switch Fuse Size

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

X401

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	No
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist