

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

**School: THEODORE ROOSEVELT HS - X, 500 EAST FORDHAM ROAD, BRONX, NY, 10458**

InspectionId	Inspection Type	Time In	Last Edited
2080058	ELECTRICAL	2010-12-15 09:07AM	2011-05-02 03:49PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephone System (Partial) Years: 2006 Systems: Intrusion Alarm System Years: 1996 Systems: IPDVS/CCTV System, Scoreboard Years: 2003 Systems: Projection System, Public Address System, Local Sound System Years: 2009 Systems: Panel Boards (partial) Years: 2003/2007 Systems: Exterior Lights Years: 1995 Systems: Local Area Network (Partial), Recessed Mounted Fluorescent Lights Years: 2008 Systems: Fire Alarm System Years: Under Construction Systems: Battery Packed Exit Lights (partial), Years: 2000/2009 Systems: Emergency Lights (Battery Packed), Emergency Light/Exit Light Panel Years: 2000 Systems: Interior Fluorescent and HID Lights Years: 1999 Systems: Motor Starters/Contactor(Partial) Years: 2010 Systems: Most Science Rooms Electrical Systems and Components Years: 1999/2007 Systems: Stage Lights Dimming System Years: 1986 Systems: Smart-board Years: 2007/2010 Systems: Switchboard - Partial Years: 2007-2009 Type of Service Below Ground

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Fire Alarm System is not Operational	Fire Alarm System	Main Entrance Lobby	Custodian-TARIFON RADEF

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st Floor
<b>HOUSE LIGHTING</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

Question	Response
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	96
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Students - 4th Floor
Instance	Teachers - 5th Floor
<b>LIGHTING</b>	
Instance on Students - 4th Floor	Inspected
Instance on Teachers - 5th Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Students - 4th Floor	Inspected
Instance on Teachers - 5th Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Students - 4th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Teachers - 5th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Students - 4th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Teachers - 5th Floor	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
Instance	Room 324A
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 324A	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 324A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 324A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 324A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 324A	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 324A	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 324A	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 324A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	
	Does not exist
<b>EMERGENCY GENERATOR SET</b>	
	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	
	Inspected
<b>BATTERY PACK</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	
	Inspected
<b>BATTERY PACK</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	4th Floor Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Non Battery Pack</b>	
Violations	No violations recorded
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Auditorium, Gymnasium 1
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Under construction
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	1st Floor - Gym 1
Instance	1st Floor - Gym 4
Instance	1st Floor - Gym 3
Instance	1st Floor - Gym 2
<b>LIGHTING</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance on 1st Floor - Gym 4	Inspected
Instance on 1st Floor - Gym 3	Inspected
Instance on 1st Floor - Gym 2	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Inspected
Instance on 1st Floor - Gym 2	Does not exist
<b>Pendant Mounted</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Gym 3	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

Question	Response
<b>GYMNASIUM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance on 1st Floor - Gym 4	Inspected
Instance on 1st Floor - Gym 3	Inspected
Instance on 1st Floor - Gym 2	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 4	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Gym 3	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
Instance on 1st Floor - Gym 2	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
Instance on 1st Floor - Gym 2	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
Instance on 1st Floor - Gym 2	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 4	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LOCAL SOUND SYSTEM</b>	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 3	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 2	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCOREBOARD</b>	
Instance on 1st Floor - Gym 1	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym 2	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st Floor - Gym 1	Does not exist
Instance on 1st Floor - Gym 4	Does not exist
Instance on 1st Floor - Gym 3	Does not exist
Instance on 1st Floor - Gym 2	Does not exist
<b>INTERCOM SYSTEM</b>	Inspected
<b>ELEVATOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HOLDING AREA</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	Students - 4th Floor
Instance	Teachers - 5th Floor
<b>LIGHTING</b>	
Instance on Students - 4th Floor	Inspected
Instance on Teachers - 5th Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Students - 4th Floor	Inspected
Instance on Teachers - 5th Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Students - 4th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Teachers - 5th Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on Students - 4th Floor	Does not exist
Instance on Teachers - 5th Floor	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 372
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 372	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 372	Inspected
<b>Pendant Mounted</b>	
Instance on Room 372	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 372	Does not exist
<b>Surface Mounted</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 372	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 372	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 372	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 372	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	3- Fair
Replacement Quantity	62
Replacement Uom	EACH
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	
Instance on Basement - Boys	Inspected
Alternative Use	No

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>LOCKER ROOM</b>	
Instance on Basement - Girls	Inspected
Alternative Use	No
<b>LIGHTING</b>	
Instance on Basement - Boys	Inspected
Instance on Basement - Girls	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Boys	Inspected
Instance on Basement - Girls	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>MOTOR CONTROL CENTER</b>	
	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	
	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Spaces

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>MOTOR STARTER/CONTACTOR</b>	
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MOTOR STARTER NOT OPERATIONAL
Deficiency Location/Instance	Main Fan Room (for Girls Gymnasium, Boys Pool), 5th Floor Fan Room (for West Elevator Exhaust)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Spaces
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room BE 1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	3rd and 4th Floor Corridors
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement, Mechanical Spaces
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Instance	Room 1A - First Floor
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 431	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 440, 442, 446	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 436, 438	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 431	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 440, 442, 446	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 436, 438	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
Instance on Room 431	Inspected
Instance on Room 440, 442, 446	Inspected
Instance on Room 436, 438	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 431	Inspected
Instance on Room 440, 442, 446	Inspected
Instance on Room 436, 438	Inspected
<b>Pendant Mounted</b>	
Instance on Room 431	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 440, 442, 446	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 436, 438	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Does not exist
<b>Surface Mounted</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 431	Inspected
Instance on Room 440, 442, 446	Inspected
Instance on Room 436, 438	Does not exist
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Instance on Room 431	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 440, 442, 446	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
<b>Surface Mounted</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 431	Inspected
Instance on Room 440, 442, 446	Inspected
Instance on Room 436, 438	Inspected
<b>Instructor Unit</b>	
Instance on Room 431	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 440, 442, 446	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 436, 438	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Meter Demonstration Unit</b>	
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on Room 431	Does not exist
Instance on Room 440, 442, 446	Does not exist
Instance on Room 436, 438	Does not exist
<b>SMART BOARD</b>	
Instance on Room 431	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 440, 442, 446	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 436, 438	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 108, 308	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 465	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 208, 242	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 212	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 437	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 238, 312	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 112A	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>LIGHTING</b>	
Instance on Room 108, 308	Inspected
Instance on Room 465	Inspected
Instance on Room 208, 242	Inspected
Instance on Room 212	Inspected
Instance on Room 437	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
Instance on Room 238, 312	Inspected
Instance on Room 112A	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 108, 308	Inspected
Instance on Room 465	Inspected
Instance on Room 208, 242	Inspected
Instance on Room 212	Inspected
Instance on Room 437	Inspected
Instance on Room 238, 312	Inspected
Instance on Room 112A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Does not exist
Instance on Room 238, 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Does not exist
Instance on Room 238, 312	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 112A	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Does not exist
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 108, 308	Inspected
Instance on Room 465	Inspected
Instance on Room 208, 242	Inspected
Instance on Room 212	Inspected
Instance on Room 437	Inspected
Instance on Room 238, 312	Inspected
Instance on Room 112A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Does not exist
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Does not exist
Instance on Room 238, 312	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>POWER SUPPLY</b>	
Instance on Room 108, 308	Inspected
Instance on Room 465	Inspected
Instance on Room 208, 242	Inspected
Instance on Room 212	Inspected
Instance on Room 437	Inspected
Instance on Room 238, 312	Inspected
Instance on Room 112A	Inspected
<b>Instructor Unit</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>POWER SUPPLY</b>	
<b>Meter Demonstration Unit</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 108, 308	Does not exist
Instance on Room 465	Does not exist
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Does not exist
Instance on Room 208, 242	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 212	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Does not exist
Instance on Room 238, 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 112A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 108, 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 465	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>SMART BOARD</b>	
Instance on Room 208, 242	Does not exist
Instance on Room 212	Does not exist
Instance on Room 437	Does not exist
Instance on Room 238, 312	Does not exist
Instance on Room 112A	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance on Room 437A	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance on Room 110, 210, 240, 310	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 466A	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 466A	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 466A	Does not exist
<b>LIGHTING</b>	
Instance on Room 437A	Inspected
Instance on Room 110, 210, 240, 310	Inspected
Instance on Room 466A	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 437A	Inspected
Instance on Room 110, 210, 240, 310	Inspected
Instance on Room 466A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 437A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 110, 210, 240, 310	Does not exist
Instance on Room 466A	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 466A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Does not exist
Instance on Room 466A	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Does not exist
Instance on Room 466A	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Does not exist
Instance on Room 466A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 466A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 466A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 466A	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 437A	Does not exist
Instance on Room 110, 210, 240, 310	Does not exist
Instance on Room 466A	Inspected
<b>Instructor Unit</b>	
Instance on Room 466A	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	
Instance	Room 167
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco-Vista 128B
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	
Deficiency Location/Instance	Room 167
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	5- Poor
Deficiency	SIREN/STROBE NOT OPERATIONAL
Deficiency Location/Instance	Wall facing E Fordham Road
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Ultrasonic Sensor</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	4th Floor Kitchen
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>IPDVS/CCTV SYSTEM</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Inspected
Instance Condition	Basement Electrical Room BE-1
Instance Quantity	3- Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Federal Pacific
Capacity/Size	Main Distribution Center #2
Source of Capacity/Size	2500 Amps
Installation Year	Nameplate
Source of Installation Year	1965
Deficiency	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Electrical Room BE-1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main Distribution Center #1
Capacity/Size	4000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	
	Inspected
Instance	Basement - Boys
Instance	Basement - Girls
<b>LIGHTING</b>	
Instance on Basement - Boys	Inspected
Instance on Basement - Girls	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Boys	Inspected
Instance on Basement - Girls	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SWIMMING POOL</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement - Boys	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Basement - Girls	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCOREBOARD</b>	
Instance on Basement - Boys	Does not exist
Instance on Basement - Girls	Does not exist
<b>SWITCHBOARD</b>	
Water Penetration In Electrical Room?	Inspected
Number of Spares	No
	3
<b>AIR CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	
	Inspected
Instance	Basement Electrical Room BE-1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	N/A
Capacity/Size	4000 Amps total, 5 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Electrical Room BE-1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	N/A
Capacity/Size	2500 Amps total, 1 section
Source of Capacity/Size	Service Switch Size
Installation Year	2007
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Electrical Room BE-1
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	PS Precision Switchboard Co.
EquipmentId	N/A
Capacity/Size	2000 Amps total, 3 sections
Source of Capacity/Size	Switchboard Mains Size
Installation Year	2009
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X435**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist