

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X963**

School: **CROTONA ACADEMY - BRONX, 639-55 ST. ANNS AVENUE, BRONX, NY, 10454**

InspectionId	Inspection Type	Time In	Last Edited
1570118	ELECTRICAL	2011-02-25 08:44AM	2011-03-01 03:19PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Smart Board Years: 2007 Systems: LAN Years: 2010 Systems: Security Lights Partial Years: 2011 Systems: Fire Alarm System Years: 2004 Type of Service Below Ground

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Exit/Emergency Lights Not Operational	Exit/Emergency Lights	TCU # 10, TCU #1 and L1	Cleaner: John Sullivan

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not exist
<b>CAFETERIA</b>	Inspected
Instance	L-1
<b>LIGHTING</b>	
Instance on L-1	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on L-1	Inspected
<b>Pendant Mounted</b>	
Instance on L-1	Does not exist
<b>Recessed Mounted</b>	
Instance on L-1	Does not exist
<b>Surface Mounted</b>	
Instance on L-1	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on L-1	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on L-1	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on L-1	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

*Electrical Inspection*

**X963**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Does not exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not exist
<b>EMERGENCY LIGHTING</b>	Does not exist
<b>EXIT LIGHT</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	TCU-1, TCU-10 and L-1
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOFF PANEL</b>	Inaccessible
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	TCU-10
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	Edwards
EquipmentId	Fire Alarm Control Panel
Capacity/Size	8 Zones
Installation Year	2004
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>MANUAL PULL STATION</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X963**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Does not exist
<b>STROBE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SUB-PANEL</b>	Does not exist
<b>TAMPER FLOW SWITCH/CHAIN</b>	Does not exist
<b>GROUNDING SYSTEM</b>	Inaccessible
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	Food Service Area: FSB
<b>LIGHTING</b>	
Instance on Food Service Area: FSB	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Food Service Area: FSB	Inspected
<b>Pendant Mounted</b>	
Instance on Food Service Area: FSB	Does not exist
<b>Recessed Mounted</b>	
Instance on Food Service Area: FSB	Does not exist
<b>Surface Mounted</b>	
Instance on Food Service Area: FSB	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Food Service Area: FSB	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Food Service Area: FSB	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	1- Good
Replacement Quantity	50
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE PHOTOCCELL NOT OPERATIONAL
Deficiency Location/Instance	Play Yard Area
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**X963**

<b>Question</b>	<b>Response</b>
<b>LIGHTING - SECURITY LIGHTS</b>	
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Inspected
Instance	L-2
<b>LIGHTING</b>	
Instance on L-2	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on L-2	Inspected
<b>Pendant Mounted</b>	
Instance on L-2	Does not exist
<b>Recessed Mounted</b>	
Instance on L-2	Does not exist
<b>Surface Mounted</b>	
Instance on L-2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on L-2	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on L-2	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on L-2	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on L-2	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on L-2	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	TCU-10
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Electrical Inspection***

**X963**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Panic Switch</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Does not exist
<b>SERVICE SWITCH</b>	Inaccessible
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inaccessible
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Does not exist